




**WATER QUALITY MONITORING UNIT
AMRIT BHAWAN, VINAY MARG, CHANAKYAPURI
QUALITY CONTROL & TECHNICAL AUDIT CELL
NEW DELHI MUNICIPAL COUNCIL
ISO 9001-2015 CERTIFIED**



1. Name & address of sender: - **PRINCIPAL, Carmel Convent School, Chanakyaपुरi, New Delhi**
2. Date of receiving/collection: - **21/7/20**
3. Sample No.: - **2020/07/13343-3344.**
4. Sealed sample (Yes/No): - **Yes**
5. Dispatch No & Date: - **D/Chem/WQMU/1835, dt- 25/07/2020**

SAMPLE NOT COLLECTED BY UNIT STAFF

**DRINKING WATER TESTING REPORT
TEST-RESULTS**

Sr. No.	Location, date & time of sample collection site	Colour (Pt-Co scale)	Taste & odour	Turbidity (NTU)	PH	Total Hardness (as CaCO ₃) (Mg/l)	TDS (mg/l)	Iron (as Fe) (mg/l)	Chloride (as Cl) (mg/l)	Residual free chlorine (mg/l)	Coliform org. MPN / (100 ml)	E.Coli MPN/100 ml
1.	Senior 'A' Building.	<5	Agreeable	0.5	7.2	4	10	0.02	2	NIL	NIL	-
2.	Junior 'B' Building	<5	~20-	0.3	7.2	8	14	0.02	4	NIL	NIL	-
3.												
4.												
5.												
BIS: 10500 2012	Acceptable Limits	05 max	Agreeable	1 max.	6.5 To 8.5	200 max.	500 max.	0.3 min.	250 max	0.2 min	NIL	NIL
	Permissible Limits (in the absence of alternate source.)	15	Agreeable	5	No relaxation	600	2000	No relaxation	1000	1	NIL	NIL

Remarks:-With respect to above tests, all the above water samples ~~except Sr. No. 3, 4, 5~~ can/cannot be considered fit for drinking purposes. However minimum residual free chlorine 0.2 mg/l should be done to avoid contamination.

Chemist
24/7/20

Bacteriologist
24/7/2020

Principal
Carmel Convent School
New Delhi-110021
24/07/2020
Lab. Technician

- Note:- 1) water samples will be destroyed after testing unless otherwise specified by party.
2) If the sample is not collected by our WQMU staff, the sender/party will be responsible for any wrong, incomplete or misleading information given by him.
3) This test report is not valid for any legal proceeding.